

CONTENTS

	TITLE	PAGE NO.
CHAPTER-1	TYPE OF HYDRO ELECTRIC DEVELOPMENT AND ENVIRONMENTAL IMPACT ASSESSMENT	1
1.1	General	1
1.2	Classification of Hydro Electric Station	1
1.3	Types of Projects	1
1.3.1	Run of the River Schemes or Diversion Schemes (without pondage)	2
1.3.2	Run of the River with Pondage Schemes	2
1.3.3	Storage Schemes	2
1.3.4	Peaking, Base Load and Frequency Regulating Capability Of Hydro Plants	2
1.3.5	Synchronous Condenser operation	5
1.3.6	Pump Storage Scheme	5
1.4	Environmental Impact Assessment (EIA)	6
1.4.1	Positive Impacts	7
1.5	Environmental Acts and Clearance of Hydropower Projects in India	8
1.5.1	Requirements for Environmental Clearance	9
1.5.2	General Conditions	9
	References	11
CHAPTER-2	TECHNO-ECONOMIC STUDIES FOR CAPACITY AND UNIT SIZE OF HYDRO ELECTRIC SCHEMES (Reviewed by Dr. S. K. Singal, AHEC)	13
2.1	PLANT CAPACITY, UNIT SIZE AND SPARE CAPACITY	13
2.1.1	Initial Development	13
2.1.2	Recent Developments	13
2.2	ECONOMIC EVALUATION CRITERIA	13
2.2.1	Initial Development	13
2.2.2	Present Criteria	14
2.2.3	Present Objectives of Tariff Policy	14
2.3	ECONOMIC & FINANCIAL ANALYSIS AND TARIFF DETERMINATION	14
2.3.1	Financial Terms and Parameters	14
2.3.1.1	Capital Cost	14
2.3.1.2	Financing Arrangements and Means of Financing	15
2.3.1.3	Debt Equity Ratio	15
2.3.1.4	Working Capital	15
2.3.1.5	Discount Factor	15
2.3.2	Financial Analysis	16
2.3.2.1	Installation Cost	16
2.3.2.2	Generation Cost	16
2.3.2.3	Benefit-Cost Ratio	16
2.3.2.4	Net Present Value (NPV)	17
2.3.2.5	Internal Rate of Return	17

2.3.3	Financial Evaluation	17
2.3.4	Tariff Determination	18
2.3.4.1	Useful Life	18
2.3.4.2	Tariff Period	18
2.3.4.3	Tariff Design	18
2.3.4.4	Tariff Structure	18
2.4	Techno-economic (optimization) studies for plant capacity, unit size and spare capacity	20
2.4.1	Site Data and Economics Criteria	20
2.4.2	Power Equation	21
2.4.3	Capacity and Unit Size	21
2.4.4	Interconnection With Grid	21
2.4.5	Operating Criteria	21
2.4.6	Modern Practice	22
2.5	Unit Size and Spare Capacity at Dehar Mega Hydro Power Plant – Example	23
2.5.1	Introduction	23
2.5.2	General Considerations	23
2.5.2.1	Unit Size	23
2.5.2.2	Characteristics of Grid	23
2.5.2.3	Load Characteristics	24
2.5.2.4	Scheduled maintenance and Seasonal Variation in Unit Capacities	24
2.5.2.5	Transportation of Heavy Packages	26
2.5.2.6	Miscellaneous Consideration – Physical Layout, Part Load Operation, etc.	26
2.5.3	Spare Generating Capacity	26
2.5.3.1	Power system with Dehar power plant of peak capacity 583 MW	26
2.5.3.2	Expectation Of Forced Outage By Probability Methods	27
2.5.3.3	Spare Generating Capacity for Forced Outages	28
2.5.3.4	Monthly Peaking Factor	28
2.5.3.5	Spare Generating Capacity Required at Dehar Power Plant	28
2.5.3.6	Effects of Interconnection	29
2.5.4	Size of Units	29
2.5.5	Conclusion	30
2.6	TECHNO ECONOMIC (OPTIMIZATION OF A CANAL DROP MEDIUM SIZE POWER HOUSE) FOR CAPACITY AND UNIT SIZE	30
2.6.1	Flow Duration	30
2.6.2	Head	30
2.6.2.1	Gross head	30
2.6.2.2	Head Loss	31
2.6.2.3	Net head	31
2.6.3	Number and Size of Units	31
2.6.3.1	Energy Resource Utilisation	31
2.6.3.2	Unit Size	31
2.6.3.3	Operating Criteria	31
2.6.3.4	Spare Capacity	33
2.6.3.5	Optimum Energy Generation	33
2.6.3.6	Part Load Operation	35
2.6.3.7	Future Provision	35
2.6.3.8	Indian Experience	35

2.6.3.9	Conclusion	35
2.7	ECONOMICS OF PUMPED STORAGE SCHEME	35
2.7.1	Cost of Generation	35
2.6.2	Cost per kW Pumped Storage Plant	36
2.6.3	Advantages	36
2.7	RECENT TRENDS	36
2.7.1	Plant Capacity and Unit Size – Bathnahan -I SHP	36
2.7.2	Araraghat Small Hydro Project	37
	<u>ANNEXURE -1</u>	38
	Guidelines for Cost Estimates for Pre Feasibility Studies (SHP)	
	<u>ANNEXURE -2</u>	38
	Electro-Mechanical Equipment Cost Guidelines	
	<u>References</u>	46
CHAPTER – 3	HYDRAULIC TURBINE CLASSIFICATION AND SELECTION	53
3.1	Introduction	53
3.2	Site Data	53
3.2.1	Net Head	53
3.2.2	Definition of Head	53
3.3	CLASSIFICATION AND TYPES OF TURBINES	54
3.3.1	Francis Turbines	55
3.3.2	Axial Flow Turbines	56
3.3.2	Impulse Turbine	66
3.3.4	Deriaz Turbine	71
3.3.5	Reversible Turbines Pumped Storage Projects	71
3.4	SELECTION OF HYDRAULIC TURBINE – GENERAL CONSIDERATION	73
3.4.1	General	73
3.4.2	Head	73
3.4.3	Discharge and Plant Rating	74
3.4.4	Specific Speed	74
3.5	SELECTION CRITERIA OF HYDRO TURBINE ABOVE 5 MW UNIT SIZE	77
3.5.1	Head Output and Type of Turbine	77
3.5.2	Efficiency	77
3.5.3	Load variations	79
3.5.4	Runner Size	79
3.5.5	Transport Consideration	79
3.5.6	Turbine Setting and Excavation Requirement	80
3.5.7	Other Considerations	81
3.6	SELECTION PROCEDURE FOR TURBINES ABOVE 5 MW UNIT SIZE	81
3.6.1	Examples of Medium and Large Turbine Selection	82
3.6.1.1	Turbine Selection of Dehar Powerhouse (4 x 165 MW) of Beas Satluj link Project	82
3.6.1.2	Example of Turbine Selection of 20 MW Unit Size (Matnar Project, Chhatisgarh)	84
3.6.1.3	Example of Turbine Selection for Medium size Low Head Schemes (Mukerian & SBC Canal Fall Projects)	85
3.7	SELECTION OF SMALL HYDRO TURBINE UPTO 5 MW UNIT	88

	SIZE	
3.7.1	Type of Scheme	88
3.7.1.1	High Head Scheme	88
3.7.1.2	Low Head Scheme	89
3.7.2	Use of Standard Turbine	89
3.7.3	Turbine Efficiency	96
3.7.4	Turbine Performance	96
3.7.5	Runner Diameter and Turbine Setting	96
3.8	SELECTION PROCEDURE OF SMALL HYDRO TURBINE UPTO 5 MW UNIT SIZE	100
3.8.1	Small Hydro in the Range 0.1 MW to 5 MW	102
3.8.2	Example of turbine selection (SHP range)	102
3.8.2.1	Sobla Power House (high head)	102
3.8.2.2	Tejpura SHP	105
3.9	Micro Hydel	106
3.9.1	Micro Hydel Range (upto 100 kW)	106
3.9.2	Step by step procedure for selection of turbine	107
3.9.3	Examples of Turbine Selection (micro hydel range)	108
	<u>References</u>	109
CHAPTER -4	TURBINE REGULATORY CHARACTERISTICS AND HYDRAULIC TRANSIENTS	111
4.1	Turbine Regulating Characteristics	111
4.2	Penstock Pressure Regulation	111
4.3	Speed Regulation	113
4.4	Speed Rise	113
4.5	Considerations for Permissible Speed Rise on Full Load Rejection	114
4.5.1	Generator flywheel effect and Stability of Turbine Governor System	114
4.5.2	Large Units (grid connected)	114
4.6	Non Frequency Control Station	115
4.7	Small Hydro (grid connected)	115
4.8	Small Hydro (isolated grid operation)	115
4.9	Micro Hydels	115
4.10	Performance Characteristics - Pressure Rise and Speed Rise Calculation	115
4.11	Mega and Large Units - Turbine Governing, Speed and Pressure Regulation, Relief Valves, Frequency Control Economic Considerations	119
4.11.1	Bhkra Left Bank – Frequency Controlling Station	119
4.11.2	Large hydro Bhakra Right Bank Power Plant with frequency controlling, capability, increase in unit size on already embedded penstock by providing extra flywheel effect	120
4.11.3	Pong Power Plant (6 x 60 MW) on Beas Dam – Elimination of surge tank	122
4.11.4	Dehar Power Plant With Frequency Controlling Capability, Provision of Surge Shaft Tank And Balancing Reservoir	124
4.12	Small Hydro Projects	125
4.12.1	1750 kW power unit to be designed for isolated operation (35% speed rise)	125
4.12.2	Rajwakti Small Hydro-Electric Project – Provision of	127

	Spilling Type Surge Tank for Economic Pressure Water System	
4.12.2	Pacha Small Hydropower Project Designed for Isolated Operation	129
4.12.2.1	Data	129
	<u>References</u>	130
CHAPTER -5	TURBINE PERFORMANCE CHARACTERISTICS (Reviewed by Dr. R. P. Saini, AHEC)	131
5.1	Turbine Performance Characteristics	131
5.2	Turbine Performance Curves for Feasibility Studies	132
5.3	Turbine Performance Characteristics – Model test	134
5.3.1	Model Testing	134
5.3.2	Turbine Performance Hill Curves	134
5.3.3	Index Testing	134
5.3.4	Model Testing in India – BHEL	134
5.4	Model Test of Typical Francis Turbine	137
5.5	Hill Curves for a typical Small Hydro Turbine	141
5.6	Hydraulic Vibration	141
5.7	Small Hydro Turbine Research and Development Laboratory4	141
5.7.1	Objectives	141
5.7.2	Facilities of the Lab	143
5.7.3	Scope	144
5.7.4	Hydraulic Parameters	145
	<u>References</u>	146
CHAPTER-6	HYDRO-TURBINE GOVERNING SYSTEM	147
6.1	Introduction	147
6.1.1	Basic Control System	148
6.2	Governor Capacity (oil servomotor)	148
6.2.1	Governor Capacity electronic Load Controller (shunt load governors)	149
6.3	Type of Governor Controller	149
6.3.1	Mechanical Controller	149
6.3.2	Electro-Hydraulic Governor – Analogue Electronics	149
6.3.3	Electro Hydraulic Governor – Digital Governors	151
6.4	Speed Sensing	151
6.4.1	Permanent Magnet Generator (PMG) For Speed Sensing	153
6.4.2	Speed Signal Generator (SSG)	153
6.4.3	Voltage Transformers	154
6.4.4	Mechanical Over speed Switch	154
6.4.5	Speed Switches	154
6.4.6	Wicket Gate/Position Indication	155
6.5	Pressure oil System	155
6.5.1	Hydraulic pressure oil system	155
6.5.2	Oil Pump	155
6.5.3	Pressure tanks	155
6.5.4	Air Compressors	155
6.5.5	Sump tank	155
6.5.6	Governor Piping	156
6.6	Control (Electronic Governor)	156

6.6.1	Control Function	156
6.6.2	PID Algorithm (Electronic Governors)	157
6.7	Performance Requirements	158
6.7.1	General	158
6.8	Governor Adjustment	159
6.8.1	Electronic Governor	159
6.8.2	Mechanical Governor	160
6.9	Load Characteristics	160
6.9.1	Bhakra Left Bank Power House & Nangal Fertiliser Load System	160
6.9.1.1	Fertilizer Factory Load Characteristics and Field Observations	160
6.9.1.2	Optimum Governor Adjustment	161
6.10	Small Hydro Governor Selection Consideration	166
6.10.1	Application of Governor Control System to SHP	167
6.10.2	Electronic Digital Controller of SHP	167
6.11	Load Controller for Micro Hydels	167
6.12	Governing System used in India for Small Hydro	169
6.13	Other Examples of Typical Governing Systems	171
	<u>References</u>	173
CHAPTER-7	TURBINE AND GOVERNING SPECIFICATIONS	175
7.1	Sample Technical Specifications of Hydraulic Turbines and Governing Equipment for Vertical Kaplan Turbines (suitable changes be made for other types)	175
7.2	Standards	176
7.3	Turbine Basic Data & General Information on Water Conductor System	176
7.4	General Information	177
7.4.1	Basic Provisions	177
7.5	Performance Guarantees and Liquidated Damages	178
7.5.1	Output and Efficiency Guarantees	178
7.5.2	Weighted Average Efficiency	178
7.5.3	Bid Evaluation With Respect to Efficiency	178
7.5.4	Output and Efficiency Tests	178
7.5.5	Penalty For Shortfall In Weighted Average Efficiency and Output	179
7.5.6	Rejection Limit	179
7.5.7	Cavitation Guarantees (For Reaction Turbine runners)	179
7.5.8	Vibrations and Noise Limit	179
7.5.9	Runaway Speed	180
7.5.10	Speed Rise, Pressure Rise and Inertia	180
7.6	Model Test	180
7.7	Rectification to Meet Guarantees	180
7.8	Stresses and Factor of Safety	181
7.9	Deviations from Technical Specifications	181
7.10	General Arrangement And Constructional Features of Turbine	181
7.10.1	General	181
7.10.2	Embedded Parts of Turbine	181
7.10.3	Foundation Parts of Turbine	182
7.10.4	Working Mechanism	182
7.10.5	Servomotors of Guide Apparatus	183
7.10.6	Runner	184

7.10.7	Oil Header	185
7.10.8	Turbine Shaft & Coupling	185
7.10.9	Guide Bearing	186
7.10.10	Turbine Shaft Gland	186
7.10.11	Mounting Of Shear Pin Contact	187
7.10.12	Plate Form In Turbine Pit & Hatch Covers	187
7.10.13	Centralised Grease Lubrication System	187
7.11	Inlet and Pressure Relief Valves	187
7.11.1	Butterfly Valves	188
7.11.2	Spherical valves	188
7.11.3	Pressure relief valves	188
7.12	Turbine Instrumentation, Control, Safety Devices and Unit Control Board	188
7.13	Governing System and Accessories	191
7.13.1	Electro Hydraulic Governor	191
7.13.1.1	Rating, Performance And Basic Provisions Of Governor	191
7.13.1.2	Performance Requirement (generally provided)	193
7.13.1.3	Working Principle	193
7.13.1.4	Constructional Features	194
7.13.1.5	Electro-Hydraulic Actuator	195
7.13.1.6	Speed Signal Generator (SSG)	196
7.13.1.7	Over Speed Device	196
7.13.1.8	Restoring Mechanism	196
7.13.1.9	Oil Pressure System	196
	<u>References</u>	198
CHAPTER -8	TURBINE AND GOVERNOR TESTING	199
	(Reviewed by Dr. R. P. Saini, AHEC)	
8.1	Shop Assembly and Tests	199
8.2	Tests on Sub Assemblies	199
8.2.1	Material Tests	199
8.2.2	Defects and Corrections	200
8.2.3	Tests on Bought out Components	200
8.3	Pre-Commissioning Field Tests	200
8.4	Commissioning Tests	201
8.5	Tests to Meet Turbine Performance Guarantee	201
8.5.1	Flow Measurement	202
8.5.2	Field Efficiency test for SHP (Small Hydro upto 25 MW)	203
8.5.2.1	Acoustic Method	203
8.5.2.2	Ultrasonic Doppler Flow Meter	203
8.6	SHP Performance Test Case	204
8.6.1	Maximum Power Output Test	204
8.6.1.1	Particulars of the Test	204
8.6.1.2	Test Results	204
8.6.2	Unit efficiency test	204
8.6.2.1	Particulars of the test	204
8.6.2.2	Load Efficiency Curve	205
8.6.3	Index Test	206
8.6.3.1	Particulars	206

8.6.3.2	Test Results	206
8.6.3.3	Curves	207
8.7	Governor Testing	207
8.7.1	Performance and testing	207
8.7.2	Factory acceptance Tests (Performance)	207
	<u>References</u>	208
CHAPTER- 9	HYDRO GENERATOR, CHARACTERISTICS AND PERFORMANCE	209
9.1	GENERAL	209
9.2	Hydro Generators Early Designs	209
9.2.1	Large Hydros	209
9.2.2	Small Hydros	210
9.3	Modern Large Hydro Generator	210
9.3.1	Design Criteria	211
9.3.1.1	Site Operating Conditions (as per IEC: 60034, IEEE C-50-12 & IS: 4722)	211
9.3.1.2	Number of starts and application of load	212
9.3.1.3	Variation from rated voltage and frequency	212
9.3.2	Transient and Emergency Duty Requirements	213
9.3.3	Rotor Surface Heating	213
9.3.4	Types of Generators and Configuration (Vertical or Horizontal)	214
9.3.5	Capacity and Rating	214
9.3.6	Electrical Characteristics	214
9.3.6.1	Generator Terminal Voltage	215
9.3.6.2	Insulation and Temperature Rise	215
9.3.6.3	Short Circuit Ratio	215
9.3.6.4	Line Charging and Synchronous Condensing Capacity	216
9.3.6.5	Reactance	216
9.3.6.6	Damper Winding	216
9.3.6.7	Efficiency	217
9.3.6.8	Total Harmonic Distortion (THD)	217
9.3.6.9	Phase Sequence	217
9.3.7	Mechanical Characteristics	217
9.3.7.1	Direction of Rotation	217
9.3.7.2	Large Generator Stator	217
9.3.7.3	Rotor Assembly Critical Speeds	218
9.3.7.4	Bearings	218
9.3.7.5	Noise Level and Vibration	218
9.3.7.6	Over speed withstand	218
9.3.7.7	Flywheel Effect	218
9.3.7.8	Cooling	219
9.3.7.9	Fire Extinguishing System	220
9.3.7.10	High Pressure Oil Injection System (For Thrust Bearing)	220
9.3.7.11	Dynamic Braking System	220
9.4	Characteristics of Large Hydro Generators of Dehar Power Plant – case study	220
9.4.1	Introduction	220
9.4.2	Megawatt Rating and Number of generating Units	222
9.4.3	Power Factor and MVA Rating	223

9.4.4	Type of Generators	223
9.4.5	Generator Flywheel Effect and Stability of turbine Governor System	225
9.4.6	Generator Parameters and Electrical Stability	226
9.4.7	Line Charging Capacity and Voltage Stability	226
9.4.8	Damper winding	227
9.4.9	Generator Characteristic and Excitation System	227
9.4.10	Seismic Considerations	227
9.4.11	Conclusions	228
9.4.12	Main Parameters of Dehar Generators	228
9.5	Small Hydro Generator Upto & Below 5 MW	228
9.5.1	General	229
9.5.2	Type of Generators	230
9.5.3	Selection and Mechanical Characteristics	230
9.5.3.1	Vertical/Horizontal Configuration	230
9.5.3.2	Speed (rpm)	232
9.5.3.3	Dimension	232
9.5.3.4	Overspeed Withstand	232
9.5.3.5	Guide and Thrust Bearings	232
9.3.5.6	Braking System	232
9.5.4	Ratings and Electrical Characteristics	232
9.5.4.1	kW Rating	232
9.5.4.2	kVA Rating and power factor	232
9.5.4.3	Frequency and Number of Phases	232
9.5.4.4	Generator Terminal Voltage	233
9.5.4.5	Stator Winding Connection	233
9.5.4.6	Excitation Voltage	233
9.5.5	Insulation and Temperature Rise	233
9.5.5.1	Synchronous Generators	233
9.5.5.2	Asynchronous (Induction) Generator	233
9.5.6	Typical Characteristics	233
9.6	Micro Hydels	234
9.7	Generator Efficiencies	234
	<u>ANNEXURE-I</u>	235
	Central Electricity Authority (Grid Standards) Regulations-2006 (Abstracts)	
	<u>ANNEXURE -2</u>	238
	Synchronous Generators: Extracts from Micro Hydel Standards issued by AHEC	
	<u>References</u>	240
CHAPTER- 10	HYDRO GENERATOR EXCITATION SYSTEMS	241
10.1	General	241
10.2	Excitation System Type	241
10.3	Steady State Excitation System Requirement	242
10.3.1	Rated Field Current	242
10.3.2	Exciter Rated Current	242
10.3.3	Exciter rated Voltage	242
10.3.4	Rated Field Voltage	243
10.4	Transient Requirements	243
10.4.1	Large Generator	243

10.4.2	Small Generator	243
10.4.3	Ceiling Voltage	243
10.4.4	Excitation System Nominal Response	244
10.5	Power System Stabilizer	244
10.6	Under Excitation Limiter	244
10.7	Over excitation limiter	244
10.8	Volts-per Hertz (V/Hz) Limiter	244
10.9	VAR or PF Control System	245
10.10	Redundancy of Equipment	245
10.11	Environmental Considerations	245
10.12	Excitation Characteristics of Mega Hydro Generators for Stability	245
10.12.1	Performance Modeling	245
10.12.1	Introduction	246
10.12.2	System Description	246
10.12.3	General Considerations	246
10.12.4	System Representation for Stability Studies	249
10.12.5	Representation of Dehar Generators	249
10.12.6	Representation of Excitation System	249
10.12.7	Representation of Governor	249
10.12.8	Exciter Response Ratio	250
10.12.9	Initial Choice of Field Voltage Limits	250
10.12.10	Transient Stability Studies With Detailed Machine Representation	251
10.12.11	Auto Reclosure, Both Dehar 400 kV Machines in Circuit Throughout-case (ii)	253
10.12.12	Auto Reclosure, One Dehar 400 kV Machine Disconnected When Line is Cleared-Case (III)	253
10.12.13	Excitation Response Recommended	253
10.12.14	Auxiliary Feedback Signals	253
10.12.15	Stabilization Feedback Signal and Transient Stability	253
10.12.16	Stabilizing Feedback Signal and Dynamic Stability	254
10.12.17	Stability Signal Recommended	254
10.12.18	Overvoltage Withstand Requirement	256
10.12.19	Conclusion	256
10.12.20	Examples	257
	<u>Appendix</u>	
	Excitation System Definition and Characteristics	258
	<u>References</u>	259
CHAPTER- 11	GENERATOR TECHNICAL & EXCITATION SYSTEM SPECIFICATION	261
11.1	Specifications	261
11.1.1	Scope	261
11.1.2	Applicable Standards	261
11.2	Type and Rating	261
11.3	Electrical Characteristics	262
11.4	Mechanical Characteristics	263
11.5	Insulation and Temperature Rise	263
11.6	Speed Rise and Runaway Speed	264
11.7	Noise Level	264
11.8	Efficiency and Output Guarantees	264

11.9	Bid Evaluation	264
11.10	Structural Details	264
11.10.1	Stator	265
11.10.2	Rotor	267
11.10.2	Shafts & Shaft Alignment	268
11.10.3	Bearings	268
11.10.5	Lubrication	269
11.10.6	Generator Cooling	270
11.10.7	Generator Housing	271
11.10.8	Space Heaters	271
11.10.9	Piping	271
11.10.10	Brakes and lifting jacks	272
11.11	Excitation System	272
11.11.1	General	273
11.11.2	Power Transformer	273
11.11.3	Power Conversion Section	273
11.11.4	Regulator and Sequencing Control	274
11.11.5	Control	275
11.11.6	Wiring	275
11.11.7	Drawings	276
11.11.8	Additional Items	276
11.12	Control, Temperature, Instruments, Gauges and Unit Control Board	276
11.12.1	Generator Stator Winding and Bearing Temperature Monitoring	276
11.12.2	Generator Rotor Winding Temperature	277
11.12.3	Vibration Detection	277
11.12.4	Generator Air Gap Monitoring	277
11.12.5	Instruments and Guages	277
11.12.6	Temperature and Level Monitoring	277
11.12.7	Alarm and Protection Trips	277
11.13	Generator Transformer Connection	278
11.13.1	Type	278
CHAPTER – 12	HYDRO GENERATOR AND EXCITATION SYSTEM TESTS	281
12.1	Introduction	281
12.2	Quality Assurance Plan at Manufacturing Works	281
12.3	Test Specification	281
12.4	Micro Hydel Generators	281
12.4.1	Type Tests	282
12.4.2	Routine tests	282
12.5	Testing of generators	282
12.5.1	Factory Assembly Test	282
12.5.2	Field Acceptance Test	283
12.5.3	Performance Test	283
12.6	Testing of generators above 5 MW unit size	283
12.6.1	Factory Assembly and Tests	283
12.6.2	Field Assembly and Tests	283
12.6.3	Performance tests on generators above 5 MW	284
12.7	Test Procedure	284
12.7.1	Dielectric Tests of Stator and Rotor Winding	284

12.7.1.1	Test Voltages	284
12.7.1.2	Duration of Application of test Voltages	284
12.7.1.3	Additional tests After Installation	284
12.7.1.4	Rewound Machine	284
12.7.1.5	Stator Winding Turn Insulation test	285
12.7.2	Insulation resistance tests and Other Diagnostic Tests	285
12.7.3	Overspeed test	285
12.7.4	Testing High Voltage Terminal Bushings	285
12.7.5	Short Circuit withstand Test	285
12.7.6	Vibration	285
12.7.7	Noise test	285
12.8	Excitation System tests	285
12.8.1	Equipment Tests	285
12.8.2	Brushless Excitation System	286
12.9	Testing Consideration of Large Generators	287
12.10	Typical specifications for testing of large generator and static potential source type excitation system	287
12.10.1	Factory Assembly and Tests	287
12.10.2	Field Tests	289
12.10.3	Performance Tests	290
12.11	Maintenance Tests of Hydro Generator Stator Insulation	291
12.11.1	Introduction	291
12.11.2	Causes of Insulation Damages	291
12.11.3	Insulation Tests	291
	<u>References</u>	293
CHAPTER - 13	LOW AND ULTRA LOW HEAD SMALL HYDRO DEVELOPEMNT	295
13.1	Introduction	295
13.2	Technology for Utilizing Low Head Hydropower	295
13.3	Hydro Turbine for Low Head	296
13.3.1	Axial Flow Turbines (Propeller Turbines)	296
13.3.1.1	Standard Tubular Turbines	296
13.3.1.2	Vertical Semi Kaplan Turbine with Syphon Intake	300
13.3.1.3	ESSEX Bulb Turbine	300
13.3.2	Cross Flow Turbine	300
13.3.3	Schneider Engine	300
13.3.4	Marine Thruster	301
13.3.6	AUR and STO Engines	301
13.4	Velocity Head Turbines	301
13.5	Kakroi Canal Fall Project	302
13.5.1	Power Potential	303
13.5.2	General Arrangement	303
13.5.3	Bypass Channel	303
13.5.4	Silt Remover	305
13.5.5	Float Operated Bypass	305
13.6	Electro -Mechanical Equipment	306
13.6.1	Turbine Generators	306
13.6.2	Turbine Generating Unit – Control System	307

13.6.3	Intake Control Gates/valve	309
13.6.4	Cost Comparison	310
13.6.7	Conclusion	311
13.7	Recent and subsequent Schemes for Ultra low head development of small hydro power	311
13.8	Standardization and Cost Reduction (ESMAP)	313
13.8.1	Techno-Economic Design Criteria for Selection	313
13.8.2	Design Criteria	313
13.8.3	Standardization	313
13.8.4	Development of Standardized Specifications for Induction Generators	315
13.8.5	Revision of Preliminary Designs Using Standardized Specifications	317
13.9	Pump Used As Turbine (PAT)	317
13.9.1	Selection of Pump as Turbine	317
13.9.2	Types of Pumps Used As Turbine	318
13.9.3	Turbines Performance of a Pump	320
	<u>References</u>	321
CHAPTER – 14	RECENT TRENDS IN HYDRO-ELECTRIC ENGINEERING PRACTICE – ELECTRO MECHANICAL WORKS	323
14.1	TEHRI HYDRO POWER COMPLEX	324
14.1.1	Introduction	324
14.2	TEHRI HYDRO POWER PLANT	324
14.2.1	Hydraulic Turbines and Auxiliaries	324
14.2.1.1	Wicket Gate Regulating Mechanism	326
14.2.1.2	Governing System	326
14.2.1.3	Main Inlet Valve	327
14.2.1.4	Butterfly Valve	327
14.2.1.5	Cooling Water System	327
14.2.1.6	Compressed Air System	327
14.2.1.7	Unit Dewatering System	327
14.2.2	Hydro Generator and Excitation System	328
14.2.2.1	Introduction	328
14.2.2.2	Stator	329
14.2.2.3	Rotor	329
14.2.2.4	Bearing	329
14.2.2.5	Braking System	330
14.2.2.6	Generator Fire Fighting System	330
14.2.2.7	Cooling System	330
14.2.2.8	Safety/Monitoring Devices	330
14.2.2.9	Excitation System	330
14.2.3	Generator Transformer	332
14.2.3.1	306 MVA Generator Transformer	332
14.2.3.2	General design features	333
14.2.3.3	Cooling system	333
14.2.3.4	Cooling control cubicles	333
14.2.3.5	Fire fighting system	334
14.2.3.6	Protections	334
14.2.3.7	External fault protection	334
14.2.3.8	Transportation from Bhopal to Tehri Site	334

14.2.3.9	Generator Transformer Comments	335
14.2.4	Underground 420 kV Gas Insulated Switchgear (GIS) and Gas Insulated Bus Ducts (GIB)	335
14.2.4.1	Introduction	335
14.2.4.2	420 kV Gas Insulated System	335
14.2.4.3	420 kV Circuit Breaker	336
14.2.4.4	Isolating Switches	337
14.2.4.5	Grounding Switches	338
14.2.4.6	Current Transformer	338
14.2.4.7	Voltage Transformer	338
14.2.4.8	SF ₆ -to -Air Bushing	338
14.2.4.9	Surge Arrestor	338
10.2.4.10	420 kV Interface Equipment – capacity voltage transformer (CVT)	338
10.2.4.11	Line Traps	339
10.2.4.12	Line Surge Arrestors	339
10.2.4.13	Partial Discharge Monitoring System	339
14.2.5	Computerise Control System	339
14.2.5.1	Computerized System Configuration	340
14.2.5.2	Software Functions	340
14.2.5.3	Power Supply System	345
14.3	KOTESHWAR HYDROELECTRIC PROJECT	345
14.3.1	Introduction	345
14.3.2	Electro Mechanical Works	345
14.3.2.1	Hydraulic Turbines and Auxiliaries	345
14.3.2.2	Generator	346
14.3.2.3	Generator Transformer	346
14.3.3	Control & Protection	346
14.4	TEHRI 1000 MW PUMPED STORAGE SCHEME	346
14.4.1	Introduction	346
14.4.2	Scheme	346
14.4.3	Machine Hall	347
14.4.4	Electro Mechanical Works	347
14.4.5	Control System	348
	References	349